

① NOTES:

- 1. CONTRACTOR SHALL VERIFY POLE SIZE AND LOCATION WITH OWNER PRIOR TO INSTALLATION.
- 2. F.D.O.T. APPROVED POLES, S641-0700 & S641-0100.

WINDLOADING NOTE:

1. ALL POLE INSTALLATIONS SHALL BE SUITABLE FOR 150 MPH WIND WITH EXPOSURE "C", IMPORTANCE FACTOR 1.15 AND APPROPRIATE GUST FACTOR PER APPLICABLE ZONE OF INSTALLATION AS DEFINED IN THE FLORIDA BUILDING CODE. THE CONTRACTOR SHALL INCLUDE WITH THE SHOP DRAWING SUBMITTAL, A POLE WIND LOADING CALCULATION SIGNED AND SEALED BY A STRUCTURAL ENGINEER REGISTERED IN FLORIDA SHOWING THAT THE PROPOSED INSTALLATIONS WILL MEET THE GIVEN WIND LOAD REQUIREMENT. CONTRACTOR SHALL ADJUST THE SIZE OF BASE AND DEPTH OF POLE AT NO ADDITIONAL COST TO MEET THE REQUIRED WINDLOADING.

SERVICE POINT DETAIL